JANUARY 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	itional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
	1	2	3	4	5	6
	OK NR	OKNR	OKNR	OKNR	OK NR	□ OK □ NR
7	8	9	10	11	12	13
OK NR	□ OK □ NR	OKNR	OKNR	OKNR	OK NR	OKNR
14	15	16	17	18	19	20
OKNR	OKNR	OKNR	OKNR	OKNR	OK NR	OKNR
21	22	23	24	25	26	27
OK NR	□ OK □ NR	□ OK □ NR	□ OK □ NR	OKNR	OK NR	□ OK □ NR
28	29	30	31	Notes:	1	
OK NR	OK NR	OKNR	OKNR			

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

FEBRUARY 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
Notes:				1	2	3
				OKNR	OK NR	OK OK NR
4	5	6	7	8	9	10
OKNR	□ OK □ NR	OKNR	OK NR	OKNR	□ OK □ NR	OK NR
11	12	13	14	15	16	17
□ OK □ NR	OKNR	OKNR	OK NR	□ OK □ NR	OKNR	OK NR
18	19	20	21	22	23	24
OKNR	OKNR	OKNR	OK NR	OKNR	OK NR	OK NR
25	26	27	28	29		
OKNR	□ OK □ NR	OKNR	OK NR	OKNR		

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

MARCH 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
31	Notes:				1	2
OKNR					OKNR	OKNR
3	4	5	6	7	8	9
OK NR	□ OK □ NR	□ OK □ NR	□ OK □ NR	□ OK □ NR	□ OK □ NR	□ OK □ NR
10	11	12	13	14	15	16
OKNR	□ OK □ NR	OKNR	□ OK □ NR	OKNR	OKNR	OKNR
17	18	19	20	21	22	23
OK NR	□ OK □ NR	OK NR	OK NR	OK NR	OKNR	OKNR
24	25	26	27	28	29	30
OK NR	□ OK □ NR	□ OK □ NR	□ OK □ NR	OK OK NR	OKNR	OKNR

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair
· ·				

APRIL 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
	1	2	3	4	5	6
	□ OK □ NR	OK NR	OKNR	□ OK □ NR	OKNR	□ OK □ NR
7	8	9	10	11	12	13
OK NR	□ OK □ NR	□ OK □ NR	OKNR	□ OK □ NR	□ OK □ NR	OKNR
14	15	16	17	18	19	20
OKNR						
21	22	23	24	25	26	27
OK NR	□ OK □ NR	□ OK □ NR	OKNR	OK NR	OKNR	□ OK □ NR
28	29	30	Notes:	·	1	
OK NR	□ OK □ NR	OK NR				

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

MAY 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	itional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
Notes:			1	2	3	4
			OKNR	□ OK □ NR	OKNR	OK NR
5	6	7	8	9	10	11
OKNR	OKNR	□ OK □ NR	OKNR	□ OK □ NR	OKNR	□ OK □ NR
12	13	14	15	16	17	18
OKNR						
19	20	21	22	23	24	25
OK NR	□ OK □ NR	□ OK □ NR	OKNR	□ OK □ NR	□ OK □ NR	□ OK □ NR
26	27	28	29	30	31	
OKNR	OKNR	OK NR	OK NR	OK NR	OK NR	

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

JUNE 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
30	Notes:					1
						OKNR
2	3	4	5	6	7	8
□ OK □ NR	□ OK □ NR	OK NR	OK NR	OKNR	OK NR	OKNR
9	10	11	12	13	14	15
OKNR	OKNR	OKNR	OK NR	OKNR	OK NR	OKNR
16	17	18	19	20	21	22
OKNR	OKNR	OKNR	OK NR	OKNR	OKNR	OKNR
23	24	25	26	27	28	29
OK NR	OKNR	OKNR	OK NR	OKNR	OK NR	OKNR

MONTHLY MAINTENANCE RECORDS

Maintenance/	UST Number	Date	Manufacturer & Part	Name of Company Conducting
Test/Equipment Failure	051 Nulliber	Repaired	Used for Repair	Maintenance/Repair

JULY 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
	1	2	3	4	5	6
	OK NR	OKNR	OK NR	OK NR	OK NR	□ OK □ NR
7	8	9	10	11	12	13
OK NR	OK NR	OKNR	OK NR	OK NR	OK NR	□ OK □ NR
14	15	16	17	18	19	20
OKNR						
21	22	23	24	25	26	27
OK NR	OK NR	□ OK □ NR	OK NR	OK NR	OK NR	□ OK □ NR
28	29	30	31	Notes:	1	
OK NR	OK NR	OKNR	OK NR			

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

AUGUST 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
Notes:				1	2	3
				OKNR	OK NR	□ OK □ NR
4	5	6	7	8	9	10
OK NR	□ OK □ NR	OKNR	OK NR	OKNR	□ OK □ NR	OK NR
11	12	13	14	15	16	17
OK NR	OKNR	OKNR	OK NR	OKNR	OKNR	OKNR
18	19	20	21	22	23	24
OKNR	OK NR	OKNR	OK NR	OKNR	OK NR	OK NR
25	26	27	28	29	30	31
OK NR	□ OK □ NR	OKNR	OKNR	OKNR	OKNR	□ OK □ NR

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

SEPTEMBER 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
1	2	3	4	5	6	7
OK NR	OKNR	OK NR	OK NR	OKNR	OKNR	OKNR
8	9	10	11	12	13	14
OKNR	OKNR	OK NR	OK NR	□ OK □ NR	□ OK □ NR	OK NR
15	16	17	18	19	20	21
OKNR						
22	23	24	25	26	27	28
OKNR	OKNR	OKNR	OK NR	OKNR	OKNR	OKNR
29	30	Notes:	1		•	1
OKNR	OKNR					

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

OCTOBER 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	itional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
Notes:		1	2	3	4	5
		□ OK □ NR	□ OK □ NR	OK NR	OK NR	□ OK □ NR
6	7	8	9	10	11	12
OK NR	□ OK □ NR					
13	14	15	16	17	18	19
OKNR						
20	21	22	23	24	25	26
OK NR	□ OK □ NR	□ OK □ NR	OK NR	OK NR	OK NR	OKNR
27	28	29	30	31	Notes:	L
OK NR	OK NR	□ OK □ NR	OK NR	OK NR		

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

NOVEMBER 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill S	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
Notes:					1	2
					OKNR	OKNR
3	4	5	6	7	8	9
□ OK □ NR	□ OK □ NR	□ OK □ NR	OK NR	□ OK □ NR	OKNR	□ OK □ NR
10	11	12	13	14	15	16
OKNR	OKNR	OKNR	OKNR	□ OK □ NR	OKNR	OKNR
17	18	19	20	21	22	23
OK NR	□ OK □ NR	OK NR	OK NR	OK NR	OKNR	OKNR
24	25	26	27	28	29	30
OK NR	□ OK □ NR	OK NR	OK NR	OK NR	OKNR	OKNR

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair

DECEMBER 2024

MAINTENANCE CHECKLIST FOR STAGE 1 SYSTEMS

STA	GE 1 VAPOR RECOVERY – Underground Storage Tanks
Fill	Side (Dual Point & Coaxial)
	Spill buckets clean and dry
	Spill bucket drain plug functioning properly (opens/closes, seals when closed)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Fill adapter on tight and in good repair (for non-swivel types)
	Fill tube in good condition
	Fill tube no fuller than 6 inches from bottom of tank to upper cut of tube
	Tank vents have properly functioning pressure vacuum vent caps
Add	litional Coaxial Fill Side (Coaxial only)
	Fill tube (if spring loaded) operates properly (doesn't jam)
	Spring loaded fill tube seals against the coaxial fitting and gasket in good repair
Vap	or Side (Dual Point only)
	Dust cap on tight and in good condition (doesn't turn) and gasket in good condition
	Vapor adapter on tight and in good repair (for non-swivel types)
	Poppet valve operates properly (pops back when depressed) and gasket in good condition

If you have a Notice of Construction permit from Spokane Clean Air, follow all permit requirements, including maintenance. Below is a maintenance schedule. Check "OK" or "Needs Repair (NR)" and initial the day equipment is checked. Add details in the table below.

Sun.	Mon.	Tue.	Wed.	Thu.	Fri.	Sat.
1	2	3	4	5	6	7
OKNR	OKNR	OKNR	OKNR	OKNR	□ OK □ NR	OK NR
8	9	10	11	12	13	14
OK NR	OK NR	□ OK □ NR	OK NR	OK NR	□ OK □ NR	□ OK □ NR
15	16	17	18	19	20	21
OKNR						
22	23	24	25	26	27	28
OK NR	OK NR	OK NR	OK NR	OK NR	OK NR	OKNR
29	30	31	Notes:	1	1	
OK NR	OKNR	OK NR				

MONTHLY MAINTENANCE RECORDS

Maintenance/ Test/Equipment Failure	UST Number	Date Repaired	Manufacturer & Part Used for Repair	Name of Company Conducting Maintenance/Repair